

This document contains extracts from the OBC relating to anchor system used for fall protection when performing exterior building maintenance or window cleaning operations.

PARAGRAPH REFERENCE	REQUIREMENT
Anchor System on Building Exterior 4.1.10.8	<p>(1) Where maintenance and window cleaning operations are intended to be carried out on the exterior of a building described in Article 2.1.1.2, anchor systems shall be provided where any portion of the roof is more than 8 m (26 ft 3 in) above adjacent ground level.</p> <p>(2) Except as provided in Sentence (3), the anchor system in Sentence (1) shall be designed, installed and tested in conformance with CSA Standard Z91, "Safety Code for Window Cleaning Operations".</p> <p>(3) Other anchor systems may be used where such systems provide an equal level of safety</p> <p>(4) The anchor system material shall be made of stainless steel, aluminum, or other corrosion resistant base material, or from steel that is hot dipped galvanized, in accordance with CSA Standard G164-M81, "Hot Dip Galvanizing of Irregularly Shaped Articles".</p>